	TE-PUFPLUS Hi-Vol PAH Air Sample Data Form
Sample Information	Full Site Name: BHP-A-2M Deployment No. 2 Clean Batch PUF Plug No. 03.23.2 KMH 4/15/21 Clean Batch Filter No. 02.17.2 KMH 4/15/21 Clean Batch Filter No.
Field Deployment and Recovery	Clean Batch PUF Plug No. 03.23.2 KMH 4/15/21 Clean Batch Filter No. 02.17.2 KMH 4/15/2 (KMH 5/20/21) Field Deployment Technician Name Steller Setup Date/Time 4/13/21 9!20 Sample Run Date 1/13/21 Flow Conditions should be STD. Flow Rate should be 225 liters/min. Once all necessary fields in Timer screen have been set, 3 things should happen: Green power light should start to blink; Timer countdown should start indicating when sampling run will commence; Status on main screen should change to "Waiting". Field Recovery Technician Name Recovery Date/Time 4/15/21 9:20 Qstd Avg Flow (liters/min) 2.24 Actual Start Date/Time 4/15/21 0:20 Qstd Volume (m³) 3.21.90 Tamb Avg (°C) 7.4 Elapsed Time (HH:MM) Pamb Avg (mmHg) 747 Flags? Expected flags: Completed, Qstd No unexpected flags [KMH 5/20/21] Sample Status: VALID VOID (circle one) Site Observations Run Day Temperatures: High 2.2 Low 3.6 Source: Weather Channel Run Day Wind/Wind Direction: SW 8 m 1/14 Run Day Sky Cover: pt Cloudy Unusual Events? (fires, major storms, construction, etc.): ost
Maintenance	Check all that apply. All weekly checks performed by Scott Keller [KMH 6/7/21] Weekly Checks: Monthly Checks: (after 5th sample run of the month) Power cords/plugs ok? Sampling head cleaned with Kim wipes? Gaskets ok? Pictures of site logbook taken? Temperature sensors within ±2°C of transfer standard? Tubing ok? Pressure sensor within ±10 mmHg of transfer standard? Timer ok? One-point flow verification within ±10% of Qstd PUFPLUS (0.225 min)? Maintenance Notes: